

SKU GB-180-5130X3QD-DR1

Job Name: Mark: Submitted By: Date: 09/05/2025

Centrifugal Downblast Exhaust Fan, Model GB-180, Belt Drive, 1/2HP, 208-230/460V, 3Ph, Motor & Drives Unassembled, 1612-2450 CFM




Model GB, belt drive centrifugal roof exhaust fans are designed to meet the general clean air exhaust requirements for industrial and commercial buildings. Units feature a fully rolled windband bead for increased stability and easy transport. Fresh outside air is drawn in under the motor cover to maximize motor life.

- •30 x 30 inch base with prepunched mounting holes for easy attachment to roof curb
- •Variable pitch adjustable motor pulley to optimize fan performance
- •26.5 x 26.5 inch recommended roof opening

Certifications

AMCA Sound &Air High Wind and Hurricane Seismic UL/cUL 705

Performance Characteristics




Air and Sound Performance

Motor HP	Max BHP	Max Fan RPM	Min Fan RPM	Ps (in. wg)	0	0.125	0.25	0.375
1/2	0.16	630	510	CFM	2,450	2,249	1,989	1,612
	0.16			Sones	6	7.1	6.8	5.8



- •Greenheck Fan Corporation certifies that the model shown herein is licensed to bear the AMCA Seal. The ratings shown are based on tests and procedures performed in accordance with AMCA Publication 211 and AMCA Publication 311 and comply with the requirements of the AMCA Certified Ratings Program.
- •Performance certified is for installation type A: Free inlet, Free outlet.
- •Power rating (BHP/kW) includes transmission losses.
- •Performance ratings include the effects of birdscreen.
- •The sound ratings shown are loudness values in fan sones at 5 ft. (1.5 m) in a hemispherical free field calculated per AMCA Standard 301. Values shown are for installation type A: free inlet hemispherical sone levels.



Construction Features

Drive Type	Belt Drive			
Impeller Type	Centrifugal Wheel			
Impeller Material	Aluminum			
Housing Material	Spun Aluminum			
Includes	Unassembled drive package			
Certifications	AMCA Sound &Air			
Certifications	High Wind and Hurricane			
Certifications	Seismic			
Certifications	UL/cUL 705			
	Motor and drives shipped			
Drive Package Description	loose			
Required Accessory	Roof curb for new installations			

Motor Information

Service Factor	1.25
Phase	3
Voltage	208-230/460
HP	1/2
Motor Enclosure	Open Drip Proof
Motor Insulation	F
NEMA Frame Size	56